



NOTES:

1. ACCEPTABLE HYDRANTS:
 *EAST JORDAN WATERMASTER 5CD250
 *KENNEDY GUARDIAN K81
 *CLOW MEDALLION
 *MUELLER SUPER CENTURION 250
 *AVK HYDRANT-2780
2. PAINT HYDRANT WITH 2 COATS OF OLD CAT YELLOW RUST-OLEUM 7448402, MILLER PAINTS 12LW0239 OR EQUAL.
3. WHEN 6" DI PIPE EXCEEDS 18' USE APPROVED RESTRAINED JOINTS.
4. HYDRANTS SHALL BE FURNISHED WITH BREAK AWAY FLANGE OR LUGS.
5. INSTALL GUARD POST AS DIRECTED. (SEE WD-17)
6. PROVIDE MINIMUM 3' CLEAR ZONE AROUND HYDRANTS IN ALL LOCATIONS IN ACCORDANCE WITH COUNTY AND FIRE CODES.
7. IN AREAS WHERE VALVE IS LOCATED OUTSIDE OF PAVEMENT STENCIL DISTANCE TO VALVE ON HYDRANT WITH 2" BLACK NUMERALS.
8. HYDRANTS NOT IN SERVICE SHALL BE COVERED WITH BLACK HEAVY DUTY LAWN AND GARDEN BAG, SECURE WITH DUCT TAPE OR ELECTRICAL TAPE.
9. REMOVE CHAINS.

 ALDERWOOD WATER & WASTEWATER DISTRICT	
FIRE HYDRANT ASSEMBLY	
DATE: 01-2025	DWG. WD-7
APPROVED BY:  ENGINEERING & DEVELOPMENT DIRECTOR	