


NOTES:

1. INSTALL AT HIGH POINTS IN THE WATER MAIN. LOCATIONS AS DIRECTED BY THE DISTRICT.
2. LOCATE AIR RELEASE DISCHARGE PIPE NEAR PROPERTY LINE OR AS DIRECTED BY THE DISTRICT.
3. IN TRAFFIC APPLICATION VAULT SHALL BE FOG TITE 2T OR BROOKS 65-TR WITH STEEL LID STACK AS REQUIRED.
4. LENGTH OF 2" TYPE K COPPER AS DIRECTED BY THE DISTRICT.
5. SST SADDLE & GATE VALVE IS REQUIRED WHEN INSTALLED ON AN EXISTING LARGE PIPE, SEE DETAIL WD-16.

	
<p>2" COMBINATION AIR AND VACUUM RELEASE VALVE</p>	
DATE: 05-2017	DWG. WD-19A
APPROVED BY: _____ DLH _____ DISTRICT ENGINEER	