



NOTES:

1. STAINLESS STEEL TAPPING TEE SHALL BE ROMAC OR SMITH BLAIR.

O.D. RANGES (INCHES)		FOR LARGER SIZES CONSULT THE DISTRICT
6"	6.59-6.99	
8"	8.62-9.06	
12"	12.90-13.30	
16"	17.15-17.55	

2. ALL WATER MAIN TAPS SHALL BE BY THE DISTRICT UNLESS OTHERWISE SPECIFIED.
3. DEVELOPER/CONTRACTOR SHALL PROVIDE ALL REQUIRED EXCAVATION AND RESTORATION.
4. DEVELOPER/CONTRACTOR TO FURNISH ALL MATERIALS AND BLOCKING.
5. PRELIMINARY EXCAVATION MAY BE REQUIRED TO VERIFY EXISTING PIPE O.D. AND MATERIAL TYPE.



TAPPING TEE AND VALVE

DATE: 05-2017

DWG. WD-16

APPROVED BY: DLH
DISTRICT ENGINEER