


**NOTES:**

1. INSTALL AT HIGH POINTS IN THE WATER MAIN. LOCATIONS AS DIRECTED BY THE DISTRICT.
2. LOCATE AIR RELEASE DISCHARGE PIPE NEAR PROPERTY LINE OR AS DIRECTED BY THE DISTRICT.
3. LENGTH OF 1" TYPE K COPPER AS DIRECTED BY THE DISTRICT.

 <p><b>LDERWOOD</b> WATER &amp; WASTEWATER DISTRICT</p>	
<b>1" COMBINATION AIR AND VACUUM RELEASE VALVE</b>	
DATE: 05-2017	DWG. WD-19
APPROVED BY: _____ DLH _____ DISTRICT ENGINEER	