


NOTES:

1. ACCEPTABLE HYDRANTS:
 *AMERICAN DARLING B-62-B-5, 250
 *CLOW MEDALLION
 *MUELLER SUPER CENTURION 250
 *AVK HYDRANT -2780
2. THOROUGHLY CLEAN & PAINT HYDRANT WITH 2 COATS OF OLD CAT YELLOW RUST-OLEUM 7448402, MILLER PAINTS 12LW0239 OR EQUAL.
3. WHEN 6" DUCTILE IRON PIPE EXCEEDS 18' USE APPROVED RESTRAINED JOINTS.
4. INSTALL GUARD POST AS DIRECTED (SEE WD-17).
5. PROVIDE MINIMUM 5' CLEAR ZONE AROUND HYDRANTS IN OR ADJACENT TO RIGHT OF WAY AND 3' OTHERWISE.
6. INSTALL NEW STORZ FITTING WHEN SPECIFIED.

	
<p>RELOCATE/REPLACE EXISTING FIRE HYDRANT ASSEMBLY</p>	
DATE: 11-2015	DWG. WD-9
APPROVED BY: _____ DLH _____ DISTRICT ENGINEER	