

REFER TO DETAIL  
WD-2 FOR BOX  
TYPE

POUR CONCRETE TO SOLID  
EARTH. CONSTRUCT  
PER WATER DETAIL WD-11.

CONCRETE BLOCK  
4" X 8" X 16" MIN.  
(SOLID)

DISTRICT APPROVED  
TEE X 4" FL

MAIN

BLOCKING DETAIL

2" MALE CAMLOCK QUICK  
CONNECT COUPLING WITH CAP  
(DRILL 1/8" HOLE IN CAP)

3" MIN./  
6" MAX

4' TYP.  
(FROM CURB IN PAVED AREAS)

36"  
MIN. COVER

INSTALL FILTER FABRIC  
AND 5/8" CRUSHED  
ROCK AT BASE

STANDARD CAST-IRON  
VALVE BOX

2" TYPE K BRASS


DISTRICT APPROVED  
TEE X 4" FL

2" X 90° EL  
BRASS FIPT

4" R/W GATE  
VALVE FL X FL

2" BRASS NIPPLE  
4" LONG MIPT

4" X 2" COMPANION  
FLANGE FIPT



### 2" BLOWOFF ASSEMBLY

DATE: 07-2017

DWG. WD-6

APPROVED BY: SDS  
DEVELOPMENT ENGINEER

NOTES:

1. LOCATE METER BOX AS DIRECTED IN LOCATION APPROVED BY THE DISTRICT.
2. USE SAME STANDARD FOR LOCATIONS IN NON-PAVED AREAS