



SERVICE TYPE AND LOCATION	H10-UNINTENDED TRAFFIC	H20-TRAFFIC RATED	ADA-NON SKID	BOX TYPE	LID TYPE
1 INCH WATER SERVICE METER BOX IN LANDSCAPE OR DRIVEWAY (SEE NOTE 1)	X		X	CARSON HW 1527BCF HDPE W/ 18" BODY OR SIGMA/RAVEN RMB-152718-SW-B	NICOR HDPE W/ BADGER AMR RECESS AND AWWD LOGO  PART # B65NLBLKALDthoCE
METER BOX IN DRIVEWAY AISLE OR THRU-WAY		X	X	OLD CASTLE / CHRISTY B1324 (CONCRETE TYPE)	B1324 SOLID CI LID (NO AWWD LOGO)
1-1/2" - 2" WATER SERVICE METER BOX IN LANDSCAPE, BEHIND VERTICAL CURB ONLY				OLD CASTLE / CARSON HDPE 1730MSBC W/ 18" BODY PEDESTRIAN ONLY	OLD CASTLE / CARSON HDPE 1730 - HDPE AMR RECESS W/ PLASTIC READER DOOR PEDESTRIAN ONLY
METER BOX IN DRIVEWAY AISLE OR THRU-WAY (SEE NOTE 1)		X	X	OLD CASTLE / CHRISTY B1730 (CONCRETE TYPE)	B1730 SOLID CI LID
2 INCH OR SMALLER DCVA				SAME AS WATER SERVICE BOX FOR LOCATION	SAME AS WATER SERVICE BOX FOR LOCATION, NO HOLE/READER DOOR.
2 INCH OR SMALLER PRV				(SEE WD-4C)	(SEE WD-4C)
BLOW OFF AND STAND PIPE ASSEMBLY IN SAME BOX		X	X	OLD CASTLE / CHRISTY B1324 AND 12" (CONCRETE TYPE)	OLD CASTLE / CHRISTY B1324 SOLID CI LID

NOTES:

- DISTRICT APPROVAL IS REQUIRED FOR INSTALLING METER BOXES IN DRIVEWAYS. REFER TO DETAIL WD-4B FOR INSTALLATION DETAIL.
- EQUIVALENT MAY BE CONSIDERED BY THE DISTRICT.

	
<b>METER BOXES AND LIDS</b>	
DATE: 18 FEB 2020	DWG. WD-2
APPROVED BY:  ENGINEERING & DEVELOPMENT DIRECTOR	