


**MANUFACTURER**

NO.	ITEM	MAT'L	SIZE	FORD	MUELLER	McDONALD
1	METER SETTER	COPPER	1"	FORD VBH94-15W-MM-44ZA-NL WITH VERTICAL INLET MUELLER 391B24104R2-80N AY MCDONALD 762P415WCPP44X15		
2	CORPORATION STOP	FOR COPPER SERVICE	1"	FB-1000-4-Q	B25008N	74701BQ
3	PIPE	COPPER	1"	FEDERAL SPEC. WW-T-799, TYPE K ASTM SPEC. B88, TYPE K A.W.W.A. SPEC. 7S-CR, TYPE K		
4	METER (FURNISHED BY AWWD)					
5	METER BOX		1"	REFER TO DETAIL WD-2 FOR METER BOX TYPE		
6	PVC CAP AT END OF TAIL PIECE					
7	ADAPTOR		1"	F.I.P.T x COMPRESSION JOINT MATCHING SETTER MANUFACT.		
8	4" DI SADDLE		1"	FORD - FSD202 4.74-5.26 O.D. (C.C. THREAD)	ROMAC - 202NS 4.5 -5.4 O.D. (C.C. THREAD)	
9	SST 1-1/4" ROUND TAG W/ ADDRESS OR LOT NUMBER FOR CLUSTERED BOXES					

- NOTES:**
- A. SPLICES - NOT ALLOWED UNLESS APPROVED BY THE DISTRICT. USE MUELLER 110 OR FORD COMPRESSION JOINT.
  - B. OWNERS ARE RESPONSIBLE FOR INSTALLING PRESSURE REDUCER ON THEIR SYSTEM TO PROTECT THEIR FACILITIES FROM HIGH PRESSURE, EXCEPT AS OTHERWISE DIRECTED BY DISTRICT.
  - C. SURFACE RESTORATION IN ACCORDANCE WITH JURISDICTIONAL AUTHORITY.
  - D. 4" OF SAND BEDDING REQUIRED ON ALL COPPER SERVICE LINES.
  - E. WHEN SIDEWALK IS INSTALLED BEHIND METER BOX, A COPPER TAILPIECE OF LIKE LENGTH SHALL BE EXTENDED TO THE PROPERTY SIDE OF WALKWAY.
  - F. ALL FITTINGS SHALL BE "LEAD FREE"



**LDERWOOD**  
WATER & WASTEWATER  
DISTRICT


---

**1" SERVICE INSTALLATION**

---

DATE: 7 JAN 2020	DWG. WD-4
------------------	-----------

---

APPROVED BY: 

ENGINEERING & DEVELOPMENT DIRECTOR