



NOTES:

1. ACCEPTABLE HYDRANTS:
 - *EAST JORDAN WATERMASTER 5CD250
 - *KENNEDY GUARDIAN K81
 - *AMERICAN DARLING B62B, HIGH PRESSURE
 - *CLOW MEDALLION
 - *MUELLER SUPER CENTURION 250
 - *AVK HYDRANT-2780
2. PAINT HYDRANT WITH 2 COATS OF OLD CAT YELLOW RUST-OLEUM 7448402, MILLER PAINTS 12LW0239 OR EQUAL.
3. WHEN 6" DI PIPE EXCEEDS 18' USE APPROVED RESTRAINED JOINTS.
4. HYDRANTS SHALL BE FURNISHED WITH BREAK AWAY FLANGE OR LUGS.
5. INSTALL GUARD POST AS DIRECTED. (SEE WD-17)
6. PROVIDE MINIMUM 5' CLEAR ZONE AROUND HYDRANTS IN OR ADJACENT TO RIGHT OF WAY AND 3' OTHERWISE.
7. IN AREAS WHERE VALVE IS LOCATED OUTSIDE OF PAVEMENT STENCIL DISTANCE TO VALVE ON HYDRANT WITH 2" BLACK NUMERALS.
8. HYDRANTS NOT IN SERVICE SHALL BE COVERED WITH BLACK HEAVY DUTY LAWN AND GARDEN BAG, SECURE WITH DUCT TAPE OR ELECTRICAL TAPE.
9. REMOVE CHAINS.



FIRE HYDRANT ASSEMBLY

DATE: 03 NOV 2020

DWG. WD-7

APPROVED BY: 
ENGINEERING & DEVELOPMENT DIRECTOR

NTS