

NOTES:

- 1. ALL D.I. JOINTS TO BE RESTRAINED WITH MEGALUG TYPE DEVICES OR APPROVED EQUAL.
- 2. ALL D.I. PIPE AND FITTINGS TO BE CERAMIC EPOXY LINED.
- 3. ENTIRE MANHOLE INTERIOR TO BE COATED WITH RAVEN 400 OR EQUAL.

