



NOTE:

1. ALL D.I. JOINTS TO BE RESTRAINED WITH MEGALUG TYPE DEVICES OR APPROVED EQUAL.
2. ALL D.I. PIPE AND FITTINGS TO BE EPOXY LINED.
3. ENTIRE MANHOLE INTERIOR TO BE COATED WITH RAVEN 400 OR EQUAL, UNLESS APPROVED OTHERWISE BY THE DISTRICT.



**DROP MANHOLE CONNECTION**

DATE: 05-2017

DWG. S-8

APPROVED BY: DLH  
DISTRICT ENGINEER