



NOTES:

1. MANHOLES SHALL BE WATER TIGHT. GROUT PICK HOLES INSIDE AND OUT.
2. SURFACE RESTORATION IN ACCORDANCE WITH STANDARD SPECIFICATIONS AND LOCAL REGULATORY AUTHORITY.
3. IN NON PAVED AREAS INSTALL 6 FT. DIAMETER CONCRETE PAD 6 INCHES THICK AROUND FRAME AND COVER. UNLESS OTHERWISE DIRECTED BY THE DISTRICT.
4. TOP OF EXISTING PIPE SHALL BE CUT AND REMOVED ONLY AFTER NEW PIPE IS TESTED AND CCTV'D.



**SADDLE
MANHOLE**

DATE: 11-2015

DWG. S-3A

APPROVED BY: DLH
DISTRICT ENGINEER