



**NOTES:**

1. MANHOLES SHALL BE WATER TIGHT. GROUT PICK HOLES INSIDE AND OUT.
2. SURFACE RESTORATION IN ACCORDANCE WITH STANDARD SPECIFICATIONS AND LOCAL REGULATORY AUTHORITY.
3. IN NON PAVED AREAS INSTALL 6 FT. DIAMETER CONCRETE PAD 6 INCHES THICK AROUND FRAME AND COVER. UNLESS OTHERWISE DIRECTED BY THE DISTRICT.



**STANDARD PRECAST  
MANHOLE**

DATE: 11-2015	DWG. S-3
APPROVED BY: <u>DLH</u> DISTRICT ENGINEER	