



GENERAL INFORMATION ONLY. REFER TO DISTRICT STANDARDS FOR MORE DETAILED INFORMATION

NOTES:

- ① GRINDER PUMP SHALL BE A E/ONE DH071 OR DR071 MODEL AND INSTALLED PER MANUFACTURERS INSTALLATION MANUAL.
- ② FORCE MAIN AND PUMP ASSEMBLIES ARE PRIVATE AND SHALL BE THE PROPERTY OWNERS RESPONSIBILITY TO MAINTAIN.
- ③ FORCE MAIN TO 6" GRAVITY LATERAL STUB CONNECTION MUST BE MADE WITH PVC REDUCER, NOT A FLEXIBLE COUPLING (SEE DETAIL SS-7).
- ④ 1-1/4" HDPE LINE SHALL BE WATER TESTED AT 80 PSI FOR 5 MINUTES.



**TYPE 3 LIFT STATION**

DATE: 05-2017

DWG. LS-7

APPROVED BY: DLH  
DISTRICT ENGINEER