



Burlington, WA Corporate Laboratory (a)  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
 Bellingham, WA Microbiology (b)  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802  
 Corvallis, OR Microbiology/Chemistry (d)  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
 Bend, OR Microbiology (e)  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Alderwood Water District  
 3626 156th Street SW  
 Lynnwood, WA 98087

Reference Number: 24-36673  
 Project: Bacteria

System Name: 164TH ST ARTESIAN WELL  
 System ID Number: 01319B  
 DOH Source Number: 00 - Distribution Sample (Bacteria)  
 Sample Type: D - Drinking Water  
 Sample Purpose: C - Compliance  
 Sample Location: 2411 164th St SW (Artesian Well #5)  
 County: Snohomish  
 Sampled By: AWWD  
 Sampler Phone:

Repeat Sample Number:  
 Lab Number: 164-70595  
 Field ID: 2511  
 Date Collected: 12/9/24 09:30  
 Date Received: 12/10/24  
 Date Set: 12/10/24 13:42  
 Date Analyzed: 12/11/24 10:48  
 Report Date: 12/11/24  
 Comment: CI2: 0.0  
 Approved By: ckk,mlh

Authorized by:

Ceann K Knox  
 Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	mlp	SM9223 B	m_241210a	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_241210a	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: <https://doh.wa.gov/community-and-environment/drinking-water/disinfection>

**NOTES:**

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

\*If data qualifiers are present, see accompanying Qualifier Definition report.