

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Alderwood Water District
3626 156th Street SW
Lynnwood, WA 98087

System Name: 164TH ST ARTESIAN WELL
System ID Number: 01319B
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: 2411 164th St SW (Artesian Well #5)
County: Snohomish
Sampled By: AWWWD
Sampler Phone:

Reference Number: 25-04236

Project: Bacteria

Repeat Sample Number:

Lab Number: 164-08793

Field ID: 5764

Date Collected: 2/10/25 09:15

Date Received: 2/11/25

Date Set: 2/11/25 12:36

Date Analyzed: 2/12/25 10:23

Report Date: 2/14/25

Comment: CI2: 0.0

Approved By: jln,mlp

Authorized by:



Jessica L Nunamaker
Microbiologist/QA Officer

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	mlh	SM9223 B	m_250211a	
3	E. COLI	Absent		per 100mL		SM9223 B	m_250211a	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: <https://doh.wa.gov/community-and-environment/drinking-water/disinfection>

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

*If data qualifiers are present, see accompanying Qualifier Definition report.