



Environment Testing  
Edge Analytical

Burlington, WA (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 - 360.757.1400  
Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802  
Corvallis, OR Microbiology/Chemistry (d)  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Alderwood Water District  
3626 156th Street SW  
Lynnwood, WA 98087

Reference Number: 25-06380  
Project: Bacteria

System Name: 164TH ST ARTESIAN WELL  
System ID Number: 01319B  
DOH Source Number: 00 - Distribution Sample (Bacteria)  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
Sample Location: 2411 164th St SW (Artesian Well #5)  
County: Snohomish  
Sampled By: AWWWD  
Sampler Phone:

Repeat Sample Number:  
Lab Number: 164-13611  
Field ID: 8387  
Date Collected: 3/3/25 09:10  
Date Received: 3/4/25  
Date Set: 3/4/25 13:06  
Date Analyzed: 3/5/25 10:38  
Report Date: 3/7/25  
Comment: Cl2: 0.0  
Approved By: ckk,jln

Authorized by:



Ceann K Knox  
Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	mlp	SM9223 B	m_250304a	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_250304a	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: <https://doh.wa.gov/community-and-environment/drinking-water/disinfection>

**NOTES:**

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

\*If data qualifiers are present, see accompanying Qualifier Definition report.