



Burlington, WA *Corporate Laboratory (a)*  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
 Bellingham, WA *Microbiology (b)*  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*  
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802  
 Corvallis, OR *Microbiology/Chemistry (d)*  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
 Bend, OR *Microbiology (e)*  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Alderwood Water & Waste Water Dist  
 3626 156 Street W  
 Lynnwood, WA 98087

Reference Number: 20-22471  
 Project: Bacteria

System Name: 164TH ST ARTESIAN WELL  
 System ID Number: 01319B  
 DOH Source Number: 00 - Distribution Sample (Bacteria)  
 Sample Type: D - Drinking Water  
 Sample Purpose: C - Compliance  
 Sample Location: 2331 164th St SW (Artesian Well #5)  
 County: Snohomish  
 Sampled By: MW  
 Sampler Phone:

Repeat Sample Number:  
 Lab Number: 164-42762  
 Field ID: 3470  
 Date Collected: 7/6/20 08:56  
 Date Received: 7/7/20  
 Date Set: 7/7/20 12:46  
 Date Analyzed: 7/8/20 9:45  
 Report Date: 7/9/20  
 Comment: Cl2: 0.0  
 Approved By: ckk,jfh

Authorized by:

*C. K. Knox*  
 Ceann K Knox  
 Lab Manager, Bellingham

| DOH# | PARAMETER      | RESULT                                | Qualifier* | UNITS     | Analyst | METHOD   | Batch     | COMMENT |
|------|----------------|---------------------------------------|------------|-----------|---------|----------|-----------|---------|
| 1    | TOTAL COLIFORM | <b>Satisfactory, Coliforms Absent</b> |            | per 100mL | jln     | SM9223 B | m_200707a |         |
| 3    | E. COLI        | <b>Absent</b>                         |            | per 100mL |         | SM9223 B | m_200707a |         |

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

**NOTES:**

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.  
 If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.  
 If data qualifiers are present, see accompanying Qualifier Definition report.