



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
 Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Alderwood Water & Waste Water Dist
 3626 156 Street W
 Lynnwood, WA 98087

Reference Number: 20-30777
 Project: Bacteria Week1

System Name: 164TH ST ARTESIAN WELL
 System ID Number: 01319B
 DOH Source Number: 00 - Distribution Sample (Bacteria)
 Sample Type: D - Drinking Water
 Sample Purpose: C - Compliance
 Sample Location: 2331 164th St SW (Artesian Well #5)
 County: Snohomish
 Sampled By: T. OBrien
 Sampler Phone: 425-787-0250

Repeat Sample Number:
 Lab Number: 164-58314
 Field ID: 3245
 Date Collected: 9/1/20 09:04
 Date Received: 9/2/20
 Date Set: 9/2/20 12:06
 Date Analyzed: 9/3/20 9:39
 Report Date: 9/4/20
 Comment: Cl2: 0.0
 Approved By: ckk,clh

Authorized by:

C. K. Knox
 Ceann K Knox
 Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier*	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	jln	SM9223 B	m_200902a	
3	E. COLI	Absent		per 100mL		SM9223 B	m_200902a	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
 If E. Coli or Faecal Coliform are present in sample do not drink the water until it is properly treated.
 If data qualifiers are present, see accompanying Qualifier Definition report.