



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 - 360.757.1400  
Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.662.7802  
Corvallis, OR Microbiology/Chemistry (d)  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Alderwood Water District  
3626 156th Street SW  
Lynnwood, WA 98087

Reference Number: 22-26671

Project: Bacteria

System Name: 164TH ST ARTESIAN WELL  
System ID Number: 01319B  
DOH Source Number: 00 - Distribution Sample (Bacteria)  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
Sample Location: 2331 164th St SW (Artesian Well #5)  
County: Snohomish  
Sampled By: AWWD  
Sampler Phone:

Repeat Sample Number:  
Lab Number: 164-51675  
Field ID: 22110  
Date Collected: 8/8/22 09:25  
Date Received: 8/9/22  
Date Set: 8/9/22 12:21  
Date Analyzed: 8/10/22 9:50  
Report Date: 8/12/22  
Comment: Cl2: 0.0  
Approved By: jln,rml

Authorized by:

Jessica L Nunamaker  
Microbiologist/QA Officer

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	mlp	SM9223 B	m_220809a	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_220809a	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: [http://www.skagitcounty.net/drinkingwater\\_](http://www.skagitcounty.net/drinkingwater_) or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

**NOTES:**

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.  
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

\*If data qualifiers are present, see accompanying Qualifier Definition report.