Detection Summary

Client: Alderwood Water & Wastewater District
Job ID: 110-10611-1
Project/Site: Alderwood Water & Wastewater Compliance

Client Sample ID: 164th St Artesian Well # 5
Lab Sample ID: 110-10611-1

PWSID Number: 01319B

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Chloride	4.9		0.10		mg/L	1		300.0	Total/NA
Nitrate as N	1.0		0.10		mg/L	1		300.0	Total/NA
Fluoride	0.12		0.10		mg/L	1		300.0	Total/NA
Sulfate	12		0.20		mg/L	1		300.0	Total/NA
Nitrate Nitrite as N	1.0		0.010		mg/L	1		NO3NO2 Calc	Total/NA
Sodium	7.0		0.10		mg/L	1		200.7	Total/NA
Arsenic	0.0050		0.0010		mg/L	1		200.8	Total/NA
Barium	0.0066		0.0020		mg/L	1		200.8	Total/NA
Chromium	0.0049		0.00090		mg/L	1		200.8	Total/NA
Hardness as calcium carbonate	77		0.66		mg/L	1		SM 2340B	Total/NA
Turbidity	0.10		0.10		NTU	1		180.1	Total/NA
Specific Conductance	180		10		umho/cm	1		SM 2510B	Total/NA
Total Dissolved Solids	130		10		mg/L	1		SM 2540C	Total/NA